

Addendum #1

ADDENDUM #1
February 08, 2024

For
Jordan School District
South Jordan Middle School Parking Lot Addition – Part II
10245 South 2700 West
South Jordan, Utah 84088

THE ITEMS LISTED IN THIS **ADDENDUM #1** WILL BECOME PART OF THE GENERAL CONTRACT AND WILL BE INCLUDED IN THE APPROPRIATE DRAWING OR SECTION AS NOTED UNDER EACH OF THE FOLLOWING ITEMS.

GENERAL

- 1.01 Geotechnical Investigation Report clarification of possible re-use of removed on site asphalt pavement: Per Section 5.1 of the Geotechnical Investigation Report, the existing asphalt pavement could be milled and used as road base and structural fill. It would best if mixed with something like road base such that the milled asphalt content does not exceed 25% so that typical compaction methods and testing can be used.
- 1.02 Access for connection to electrical panels in the corridor of the building may require cut-in of the existing gypsum board/glue-up acoustical tile ceiling. Provide a 24" square opening in the ceiling. Coordinate exact location with the existing suspended ceiling system framing and size as required to accommodate a new ceiling access door assembly. Access door assembly shall be as follows:
 - 1.02.1 WB AL 1600 Series Aluminum Access Door, as manufactured by The Williams Bros. Corporation of America, or equal.
 - 1.02.1.1 Extruded .063 Aluminum
 - 1.02.1.2 Finish: White baked enamel.
 - 1.02.1.3 Latch: Flush, aluminum cam latch.

ELECTRICAL

- 1.01 See attached one-page Addendum from BNA Consulting dated 07 February 2024.

END OF ADDENDUM #1

SOUTH JORDAN MIDDLE SCHOOL PARKING LOT ADDITION

Electrical Addendum #1

Issue Date: 2/7/2024

CLARIFICATION TO THE BIDDERS:

PRIOR APPROVAL OF MANUFACTURERS OF ELECTRICAL EQUIPMENT

The following items, trade names, products, and manufacturers are approved for bidding. Approval does not relieve the bidder from satisfying the intent of the requirements of drawings, specifications, and addenda in every respect. Failure to conform to the design quality and standards specified, established, and required may result in later disapproval. If equipment must be disapproved after bidding, the supplier shall supply specified equipment at no extra cost to the Owner.

Items are listed generally and specific model numbers, etc. shall be as submitted. Items submitted but not approved either did not satisfy the requirements, or showed insufficient data, or arrived after the 8-day deadline established for submittals.

<u>TYPE</u>	<u>SPECIFIED</u>	<u>SSCO APPROVED</u>	<u>QUANTUM APPROVED</u>	<u>JRC APPROVED</u>
OP2A	NLS LIGHTING	VISIONAIRE	McGRAW-EDISON	LITHONIA
OP14	NLS LIGHTING	VISIONAIRE	McGRAW-EDISON	LITHONIA
OP22	NLS LIGHTING	VISIONAIRE	McGRAW-EDISON	LITHONIA
OP24	NLS LIGHTING	VISIONAIRE	McGRAW-EDISON	LITHONIA

END OF ELECTRICAL ADDENDUM