

ALTA HIGH SCHOOL GYM FIRE PROTECTION

ADDENDUM #3

CLARIFICATION TO BIDDERS:

- Provide head guards for sprinkler heads in gym area as called out in specification.
Section 21 000-3 - 2.3 -F

CHANGES TO SPECIFICATION:

- Add to section 23 0000 -3 2.2 RISERS
D. Provide knox lock caps at FDC coordinate with AHJ

CHANGES TO DRAWINGS:

ALTA HIGH SCHOOL GYM FIRE PROTECTION**Electrical Addendum #1****Issue Date:3/13/2024****CLARIFICATION TO BIDDERS:****CHANGES TO THE DRAWINGS:**

SHEET E101

1. Provide a horn/strobe in the ceiling of each (2) exit corridor/vestibule and provide conduit and wire as required to connect to the local notification loop.

END OF ELECTRICAL ADDENDUM